



RB ENVIRO LABORATORIES (OPC) PRIVATE LIMITED

Plot No. 56, First Floor, Shivalik City-Nijjer Road, Sec. 127, Kharar, SAS Nagar, Mohali

ISO 9001: 2015, ISO 14001:2015, ISO 45001:2018

GSTIN : 03AANC1768G1Z9, Email: rbenvirosolution@gmail.com

+91 6239447329, 8437473298

Page 1 of 1

To
M/s MADHAV KRG HRC PVT LTD.
VILLAGE AKALGARH, NEAR TOLL PLAZA, AMLOH
BHADSON ROAD, BHADALTHUHA, PATIALA, PUNJAB-147203

Report No.	RBEL/2605/095X	Report Date	19.05.2026
Your Ref. No.	Nil	Type of sample	STP Outlet
Sample Code given by customer	Nil	Quantity	2 Liter HDPE Bottle + 1 Liter Glass Bottle
		Date of sampling	13.05.2026
		Date of sample receipt	14.05.2026
Sampling Location	Within Premises	Sample I.D.	RBEL/2605/095X
Sample Collected By	Lab Person	Date of test	14.05.2026-19.05.2026
Sampling procedure	As per SOP		

S. NO.	PARAMETERS	TEST RESULTS	Limits	TEST METHODS
		7.53	5.5 - 9.0	IS 3025 (Part-11): 2002
1.	pH	18	100	IS 3025 (Part-17): 1984
2.	Total Suspended Solids, mg/L	690	2100	IS 3025 (Part-16): 1984
3.	Total Dissolved Solid, mg/L	09	10	IS 3025 (Part-44): 2003
4.	Bio-chemical Oxygen Demand at 27°C 3 days, mg/L	42	50	IS 3025 (part-58): 2006
5.	Chemical Oxygen Demand, mg/L	3.3	10	IS 3025 (Part-39): 2003
6.	Oil and Grease, mg/L	196	...	IS 3025 (Part-21): 2009
7.	Total Hardness (as CaCO ₃) mg/l.	40	...	IS 3025 (Part-23): 2003
8.	Alkalinity (as CaCO ₃) mg/l	0.15	03	IS 3025 (Part-53): 2003
9.	Iron (as Fe) mg/l	1007	...	IS 3025 (Part-14): 1984
10.	Conductivity, micro mhos/cm at 25°C	0.18	05	IS 3025 (Part-31): 2003
11.	Total Phosphate as PO ₄	152	...	IS 3025 (Part-32): 2007
12.	Chloride (as Cl), mg/l.	02	...	IS 3025 (Part-10): 2002
13.	Turbidity, NTU max			

Note: ND Denotes Not Detectable

1. The test report refers only to tested sample and applicable parameters.
2. This report can neither be used as evidence in the court of law nor can it be used in part or full in any media without prior permission.
3. The sample will be destroyed after fifteen days from the date of issue of test report unless otherwise specified.

(Authorized Signatory)

End of Report

communicated in writing within 15 days of the dispatch of Test Report.

8437473298 62394 473298